Energy performance certificate (EPC)			
17 The Diamond BT52 1DW	Energy rating	Valid until: 21 March 2032 Certificate number: 3549-7345-1054-3794-2886	
Property type		A1/A2 Retail and Financial/Professional services	
Total floor area		113 square metres	
<b>Energy efficiency rating for this property</b> This property's current energy rating is F.		Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.	
Under 0 <b>A+</b> 0-25 <b>A</b>		How this property compares to others Properties similar to this one could have ratings:	
26-50         B           51-75         C           76-100         D           101-125         E		If newly built 37   B	
126-150 <b>F</b> 139  F Over 150 <b>G</b>		If typical of the existing stock	

Properties are given a rating from A+ (most efficient) to G (least efficient).

# Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	120.3
Primary energy use (kWh/m2 per year)	679

## **Recommendation report**

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/8477-6325-9675-8885-6368)</u>.

### Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

#### Assessor contact details

Assessor's name Telephone Email

#### Accreditation scheme contact details

Accreditation scheme Assessor ID Telephone Email

#### **Assessment details**

Employer Employer address

Assessor's declaration

Date of assessment Date of certificate Declan Heggarty 07595362912 info@nienergyrating.com

Stroma Certification Ltd STRO001014 0330 124 9660 certification@stroma.com

Northern Ireland Energy Rating 3 The Everglades, Clare Road, Ballycastle, County Antrim BT54 6BE The assessor is not related to the owner of the property. 21 March 2022 22 March 2022